

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building: ST. BASIL'S CHURCH Names of Inspectors: MICHAEL GRAMM Names of Inspectors: PETER SUPERCHUK
 First Aid Box Checked? Yes / No Date: MAY 17, 2024 Signed: [Signature] Signed: [Signature]
 Eyewash Station Checked? Yes / No

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete Date	Initials
STEAM	DOG HOUSE	COVER NEEDED ON OPEN RECEPTACLE		C		I WILL REPLACE COVER	27/05/24	MC
KITCHEN	PANTRY	REPLACE CRACKING TILE			30138536	WILL REPLACE TILE	27/05/24	MC
AED	WALKWAY KITCHEN	PADS EXPIRED FOR AED			30138554	NOTIFY HR. / CHURCH TO REFRESH.	27/05/24	MC
BSMT	NEWS WASHROOM	SHOWER LOCKED				MAKE SURE KEY AT FRONT DESK		LD
LAUNDRY ROOM	BSMT	- SOME FLAMMABLE MATERIALS IN ROOM (VARNISH ETC)						
LAUNDRY ROOM		WINDOW WILL NOT LOCK			30138560	W.O TO REPLACE HASP	27/05/24	MC

[Signature]



January 13, 2025

Effie Slapnicar
 Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building:	ST. BASICS CANTON	Names of Inspectors:	M. GRIFFIN	Names of Inspectors:	PETER SKREPICHUK
First Aid Box Checked?	<input checked="" type="checkbox"/> Yes / No	Date:	MAY 17, 2024.	Signed:	
Eyewash Station Checked?	<input checked="" type="checkbox"/> Yes / No			Signed:	

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
STORAGE		PEZZINE PAINT. REQUIRES PATCHING	PAINT CHIPS GETTING IN TOYS ETC.			PAINTER TO REMOVE & REPAINT. DISCUSS WITH STEVE C.		
BSMT. SOUTH								




January 8, 2025

Effie Slapnicar
 Bursar & Chief Administrative Officer


Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building:	COACH HOUSE	Names of Inspectors:	MICHAEL GILHAM	Names of Inspectors:	
First Aid Box Checked?	Yes / No	Date:	JAN 24, 2024	Signed:	
Eyewash Station Checked?	Yes / No			Signed:	

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
UPPER COACH HOUSE		PIGEON DEBRIS TO BE CLEANED	A ^U C ILLNESS	C		W.O. PLACED TO HAVE FERRO-CLEAN	25/01/24	MG
LOWER COACH HOUSE		LIGHTING GOOD			29587017			

 January 8, 2025

Effie Slapnicar
 Bursar & Chief Administrative Officer

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.



UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	Brennan Residence	Date: May 5-23	
First Aid box checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO	Name of Inspector:	John Santos
Eyewash station checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO		

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action
Upper Brennan	all Rooms	Nothing was found	—	—	—	—

January 8, 2025

Effie Slapnicar
Bursar and Chief Financial Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.



UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	Elmsley Residence	Date:	May 9/10/23
First Aid box checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO	Name of Inspector:	John Santos
Eyewash station checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO		

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action
Elmsley	all Rooms	Nothing was found	—	—	—	—

January 8, 2025 _____

Bursar and Chief Financial Officer

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.



UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	Fisher House	Date:	15 - May 15 - 23
First Aid box checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO	Name of Inspector:	John Santos
Eyewash station checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO		

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action
Fisher	all rooms	Nothing was found	-	-	-	-

Effie Slapnicar
Bursar and Chief Financial Officer

January 8, 2025

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.



UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	more House	Date:	May 16-23
First Aid box checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO	Name of Inspector:	John Santos
Eyewash station checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO		

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action
more	all Rooms	Nothing was found	—	—	—	—

January 8, 2025

Effie Slapnicar
Bursar and Chief Financial Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.



UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	House-2 McCorkell and House 296 Sullivan	Date: May 18-23	
First Aid box checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO	Name of Inspector:	John Santos
Eyewash station checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO		

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action
H2 H96	all Rooms	Nothing was found	-	-	-	-

Effie Slapnicar
Bursar and Chief Financial Officer

January 8, 2025

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for serious injury, illness, or property damage that is disruptive, but less than Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.



UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	Keefy Residence	Date:	May-23-23
First Aid box checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO	Name of Inspector:	John Santos
Eyewash station checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO		

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action
Keefy	all rooms	Nothing was found	-	-	-	-

Effie Slapnicar
Bursar and Chief Financial Officer

January 8, 2025

Date

***Hazard Class:**

Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for serious injury, illness, or property damage that is disruptive, but less than Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.



UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	House 6/8 - Maritain and Gibson	Date: May 25-23	
First Aid box checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO	Name of Inspector:	John Santos
Eyewash station checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO		

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action
H/6/8	all rooms	Nothing was found	—	—	—	—

Effie Slapnicar
Bursar and Chief Financial Officer

January 8, 2025

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.



UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	Sorbara Residence	Date: May 29-30-23
First Aid box checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO	Name of Inspector: John Santos
Eyewash station checked?	<input type="checkbox"/> YES / <input checked="" type="checkbox"/> NO	

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action
Sorbara	all rooms	Nothing was found	—	—	—	—

Effie Slapnicar
Bursar and Chief Financial Officer

January 8, 2025

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

	<i>U Park Mech Mechanical</i>	of Inspectors: <i>KE GRAHAM</i>	Names of Inspectors:
Box Checked? Yes / No	Date: <i>Nov 6, 2023</i>	Signed: <i>Michael Chow</i>	Signed:
Station Checked? Yes / No			

	Room	Description	Special Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Date	Initials	Complete
<i>T BSM EL</i>	<i>T PHONE ROOM</i>	<i>ATTENOS R/T</i>	<i>REPAIR IN CASE OF OUTAGE</i>	<i>C</i>		<i>CONTACT SERVICE OWNERS</i>	<i>May 2024</i>	<i>M.G.</i>	
<i>BSMT</i>	<i>LEV. / ARCH ROOM</i>	<i>VAULTING NOT</i>	<i>AIR REMOTE CONTROL</i>	<i>C</i>		<i>CONTACT MECHANICAL</i>	<i>Nov 20</i>	<i>M.G.</i>	
<i>BSMT</i>	<i>ELECT. CONTROL ROOM</i>	<i>4 VARS WESSY</i>	<i>M.I. W.O. CONDITION</i>			<i>CALL ROOM</i>		<i>W.P.</i>	
<i>3RD</i>	<i>FAN ROOM</i>	<i>STEEL RIG ROOM</i>	<i>TRIPPING HAZARD</i>			<i>REMOVE STEEL AT ENTRANCE</i>	<i>March 6, 2024</i>	<i>M.G.</i>	
						<i>- Michael Chow noted that the work to be done risks more danger than to the benefit of completion. May need revisiting in the future. No current action required.</i>			



January 8, 2025


Effie Slapnicar
Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury illness. However does require follow-u & remedy. p

UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	EUMSLEY OFFICE / BSMT	Names of Inspectors: MIKE GRAHAM	Names of Inspectors:
First Aid Box Checked?	Yes / No	Date: Nov 6, 2023	Signed:
Eyewash Station Checked?	Yes / No		Signed: 

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
ACC. OFFICE	EUMSLEY	CARPET LOOSE NEAR WINDOW	TRIPPING HAZARD	C	NONE	GLUE CARPET DOWN (GLUED DOWN CARPET)	Nov 6 2023	MG
ACC. OFFICE	EUMSLEY	No EXIT. SIGN.	NOT KNOWING EXIT IN FIRE	C	27363 27363 894	ORDER SIGN.	Nov 9 2023	SC
BSMT	EUMSLEY	LIGHTING SUBSTANDARD	TRIPPING HAZARD	C	27364 022	HAVE G.C. UPGRADE LIGHTING	Nov 9 2023	SC



January 8, 2025


Effie Slapnicar
Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	TEEFY CLASSROOMS / MECH.	Names of Inspectors: MIKE GRAHAM	Names of Inspectors:
First Aid Box Checked?	Yes / <input checked="" type="radio"/> No	Date: NOV 16, 2023	Signed:
Eyewash Station Checked?	Yes / <input checked="" type="radio"/> No		Signed: 

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
TEEFY	103	CABLES ON FLOOR	TRIPPING HAZARD	C	2747 3325	INSTALL COVER.	NOV 16 2023	MG
TEEFY	7	SHELF NOT SECURED	TIPP OVER	C	2747 3378	SECURE TO WALL	NOV 16 2023	MG
Mech ROOM		MECH ROOM IN ORDER						



January 8, 2025


Effie Slapnicar
Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	CARR MECHANICAL	Names of Inspectors: MICHAEL GRAHAM	Names of Inspectors:
First Aid Box Checked?	Yes/No N/A	Date:	Signed:
Eyewash Station Checked?	<input checked="" type="checkbox"/> Yes/ No	NOV-17, 2023	

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
BSMT	BOILER / MECHANICAL		EMERGENCY LIGHTING O.K. EXIT LIGHTS			EYEWASH STATION 0.12	N.A Not needed	C.B



January 8, 2025

Effie Slapnicar
Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	ALUMNI MECHANICAL	Names of Inspectors: MIKE GATHAM	Names of Inspectors:
First Aid Box Checked?	<input checked="" type="radio"/> Yes / No	Date: Nov 24, 2023	Signed:
Eyewash Station Checked?	<input checked="" type="radio"/> Yes / No	Signed: <i>Michael Hall</i>	Signed:

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
PENTHOUSE MECHANICAL		- EXIT LIGHTS IN ORDER - EYE WASH STATION O.K.					N.A.	C.B.
		- MECHANICAL ROOM CLEAN & FREE OF DEBRIS - ELEVATOR MACHINE ROOM IN GOOD SHAPE						



January 8, 2025

Effie Slapnicar
Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building:	KELLY MECHANICAL	Names of Inspectors: MICHAEL GRAHAM	Names of Inspectors:
First Aid Box Checked?	Yes / No	Date:	Signed:
Eyewash Station Checked?	<input checked="" type="radio"/> Yes / No	DEC 1, 2023	<i>Michael Graham</i>

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
PENTHOUSE	MECH. ROOM	- EYE WASH CHECKED - EXIT / EMERG. LIGHTS IN ORDER - MECHANICAL ROOM HAS NO DEBRIS / CLEAN. - VENTILATION FAN IN ORDER FOR REF. ALARM					N.A.	C.B.
		* NO ACTION NEEDED						



January 8, 2025

Effie Slapnicar
 Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	COACH HOUSE	Names of Inspectors:	Names of Inspectors:
First Aid Box Checked?	Yes / No	Date:	Signed:
Eyewash Station Checked?	Yes / No	JAN 24, 2024	Signed:

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
UPPER COACH HOUSE		PIGEON DEBRIS TO BE CLEANED	R ^U C ILLNESS	C		W.O. PLACED TO HAVE FERRO. CLEAN	25/01/24	MG
LOWER COACH HOUSE		LIGHTING GOOD			29587017			



January 8, 2025

Effie Slapnicar
Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building:	2/96 MECHANICAL	Names of Inspectors: MIKE GRIFFIN	Names of Inspectors:
First Aid Box Checked?	Yes / No	Date:	Signed:
Eyewash Station Checked?	<input checked="" type="checkbox"/> Yes / No	JAN 31, 2024	

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
BSMT MECH.		No EYEWASH STATION	UNABLE TO FLUSH EYES	C		ORDER + INSTALL -	APRIL 1 2024	MG




January 8, 2025

Effie Slapnicar
 Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building:	6/8 MECHANICAL	Names of Inspectors: MIKE GRAHAM	Names of Inspectors:
First Aid Box Checked?	Yes / No	Date:	Signed:
Eyewash Station Checked?	<input checked="" type="checkbox"/> Yes / No	JAN 31, 2024	

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
MECH BSMT	MECHANICAL	EYEWASH STATION SIGN REMOVED FROM DOOR	UNABLE TO LOCATE	C		HAVE GANG PLEASE MAKE SIGN FOR ME	APR 1 2024	MG
	MECHANICAL	WOOD BASEBOARD LEFT IN ROOM	TRIPPING	C		REMOVE SAME	MARCH 08 2024	MG



January 8, 2025

Effie Slapnicar
 Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building:	PHELAN HOUSE	Names of Inspectors: MICHAEL GRAMHAM	Names of Inspectors:
First Aid Box Checked?	Yes / No	Date: APR 3, 2024	Signed:
Eyewash Station Checked?	Yes / No		Signed: <i>Michael</i>

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
STAIRS To FATHER FARGES		STAIR TREADS NEEDED REPAIR	FALL	C		STEVE CRAIG HAD CONTRACTOR RE-CARPET.	COMPLETED @ JANUARY 23	C.B.
BSMT SOUTH STAIR		DOOR HAS HARD TIME CLOSING FROM OUTSIDE	GET HAND CAUGHT IN LOCK/DOOR	C.		PLACED W.O. FOR LOCKSMITH 29586938. Extra deadbolt was installed.	04/17/24	C.B.

Effie Slapnicar

January 8, 2025

Effie Slapnicar
Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less than Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building:	WINDLE HOUSE	Names of Inspectors: MICHAEL GRAHAM	Names of Inspectors:
First Aid Box Checked?	Yes / No	Date: APRIL 3, 2024	Signed:
Eyewash Station Checked?	Yes / No		Signed: Michael G

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
ATTIC	ACCESS TO ROOF	NEED LOCK & HASP TO PREVENT ENTRY	FALL	C	29586988	INSTALL LOCK & HASP.	11/29/24	MG
2ND FLOOR	SHELVING UNIT.	SHELVING UNIT NEEDS SECURING	SHELVES FALL ON SOMEONE	C	29586978	SECURE SHELVING	11/29/24	MG
S/E PATHWAY		PATH NEEDS LEVELLING	FALL	C	29586954	RESCOPE PATH.	INSTALLED Pylon FOR WARNING	



January 8, 2025

Effie Slapnicar
 Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less than Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building:	QUEENS PARK MECH	Names of Inspectors: MICHAEL GRAHAM	Names of Inspectors:
First Aid Box Checked?	Yes / No	Date: APRIL 17, 2024	Signed:
Eyewash Station Checked?	Yes / No	Signed: Michael Gil	Signed:

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
BSMT MECH		ROOM CLEAN / CLEAN OF DEBRIS. EMERG LIGHTING OPERATES.		NO RECOMMENDATIONS			N.A.	C.B.



January 8, 2025




Effie Slapnicar
 Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	PENTHOUSE MECH CORETTO	Names of Inspectors: EMIL Ivthasathos	Names of Inspectors: MIKE GRAHAM
First Aid Box Checked?	<input checked="" type="radio"/> Yes / No	Date: APRIL 18, 2024	Signed: 
Eyewash Station Checked?	<input checked="" type="radio"/> Yes / No	Signed: 	Signed: 

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
Boiler Room		EYE WASH STATION SIGN ON DOOR TO MECH ROOM NEEDED	HARD TO FIND	C	29603184	Gang installed sign to indicate location. PLACE W.O TO GANG HE & INSTAL	19/04/24	MC
Boiler Room		FIRST AID STATION TO BE MOUNTED ON WALL RESTOCK BOX (CINTAS)	29618836	C		ASK CHANELLE BY EMAIL APRIL 18, 2024 <small>Chanelle added boiler room to first aid list and was checked in Sept. 2024</small>	APR 18	C.B.
Boiler Room		EXIT LIGHT LEAVING ROOM (3)	HARD TO FIND IN EMERGENCY	C		W.O TO G.C. (NOT NEEDED) ELECTRIC (EMAIL STEVE C.)		MC
PATIO	EGRESS	EXIT LIGHT EAST/WEST ROOF	NOT SHOWING EXIT PATH	C		(SCHEDULED FOR REPLACEMENT) W.O TO GC (EMAIL STEVE C.) ELECTRIC		C.B. COMPLETE MAY 2024
						G.C. added a new light in May 2024.		



January 8, 2025



Effie Slapnicar
Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	LORETTO COLLEGE RESIDENCE	Names of Inspectors: EMIL IRUTHAYATHAS	Names of Inspectors: MIKE GRAHAM
First Aid Box Checked?	<input checked="" type="radio"/> Yes / No	Date: APRIL 18, 2024.	Signed: 
Eyewash Station Checked?	<input checked="" type="radio"/> Yes / No		Signed: 

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
3RD FLOOR SWP SINK	CLEANING	EYE WASH REQUIRED	FLUSH EYE	C		EMAIL NETLIA / DISCUSS - Michael Chow initiated distribution of small personal eyewash bottles across campus including Loretto College.	COMPLETED Feb. 29, 2024	C.B.
2ND FLOOR SWP SINK	CLEANING	EYE WASH REQUIRED	FLUSH EYES FROM CHEMICALS	C		DISCUSS - Michael Chow initiated distribution of small personal eyewash bottles across campus including Loretto College.	COMPLETED	C.B.
LAUNDRY ROOM		RELOCATE FIRST AID KIT TO THE WALL	OBSTRUCTED RIGHT NOW	C	29618857	MOUNT ON WALL MIKE + PUSHPA.	19/04/24	MG
LAUNDRY ROOM		MOUNT SIGN ON WALL EYE-WASH		C	29618857	MOUNT ON WALL MIKE + PUSHPA.	19/04/24	MG
JESUIT OFFICE		2 SHELVES TO BE ANCHORED			29603127	W.O. CREATED.	19/04/24	MG

5TH FLOOR STATION (FIRST-AID) FULLY STOCKED.
 422 - FIRST AID KIT INSIDE ROOM / 4TH FLOOR FIRST AID O.K.
 3RD


 Effie Slapina
 Bursar & Chief Administrative Officer

January 8, 2025

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building:	SORBETA MECHANICAL Basement	Names of Inspectors: MICHAEL C. MAHAM	Names of Inspectors:
First Aid Box Checked?	Yes / No	Date:	Signed:
Eyewash Station Checked?	<input checked="" type="radio"/> Yes / No	APRIL 25 / 2024	<i>Michael Maham</i>

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
BSMT MECH		ROOM CLEAN & CLEAR OF DEBRIS.	EYEWASH STATION O.K.			NO RECOMMENDATIONS		



January 8, 2025

Effie Slapnicar
 Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.


UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report


Location: Boiler House Names of Inspectors: MICHAEL GRAHAM Names of Inspectors: _____
 First Aid Box Checked? Yes / No Date: APRIL 25, 2024 Signed: [Signature] Signed: _____
 Wash Station Checked? Yes / No

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
Boiler Room		CRUMBING CONCRETE	ROCKY REBAR COULD FALL	C		ROJECT - M. BERDA TO REMOVE & POUR NEW SLAB / W. REPAIR	2024-12-12	FALL C.B.
						Project Complete - December 12, 2024		

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury illness. However, does require follow-up & remedy.


 Effie Slapnicar Date: January 8, 2025
 Bursar & Chief Administrative Officer

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building:	Historical Houses 2/96	Names of Inspectors: John Santos	Names of Inspectors: John Santos
First Aid Box Checked? Yes / No	Date: May 7/8	Signed:	Signed: 
Eyewash Station Checked? Yes / No			

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
all Floor	all Rooms	Nothing to Report	—	—	—	—	May 7/8	J.S.

***Hazard Class:**
Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
Class "D" – No potential of injury / illness. However, does require follow-up & remedy.





January 8, 2025

Effie Slapnicar
Bursar & Chief Administrative Officer

Date

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building:	Historical 6/8 Houses	Names of Inspectors: John Santos	Names of Inspectors:
First Aid Box Checked? Yes / No	Date: May 9 / 10	Signed: 	Signed: 
Eyewash Station Checked? Yes / No			

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
all Floor	all Rooms	Nothing to Report	—	—	—	—	May 9 / 10	S.S.

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.




January 8, 2025

Effie Slapnicar
 Bursar & Chief Administrative Officer

Date

UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	ODETTE HALL	Names of Inspectors: M. GRIHAM	Names of Inspectors: PETER SKREPICHUK
First Aid Box Checked?	<input checked="" type="checkbox"/> Yes / No	Date: MAY 17, 2024	Signed:
Eyewash Station Checked?	<input checked="" type="checkbox"/> Yes / No		

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
2/3 STAIRWELL		DRYWALL PULLING FROM WALL		30139105		INVESTIGATE - FIND CAUSE.. Work in progress.	N.A.	C.B.
EAST EXIT TO	ODETTE	OUTDOOR LIGHTING NOT WORKING		30910027		DISCUSS IF NEEDED WITH LEAD HANDS	18-09-24 <i>Jan 24/25</i>	C.B.



January 8, 2025



Effie Slapnicar
Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	ST. BASIL'S CHURCH	Names of Inspectors: MIKE GRAMM	Names of Inspectors: PETER SUREPICHUK
First Aid Box Checked?	<input checked="" type="checkbox"/> Yes / No	Date: MAY 17, 2024	Signed:
Eyewash Station Checked?	<input checked="" type="checkbox"/> Yes / No	Signed: 	Signed: 

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
STEAM DOG HOUSE		COVER NEEDED ON OPEN RECEPTACLE		C	30138536	I WILL REPLACE COVER	27/05/24	MC
KITCHEN PANTRY		REPLACE CEILING TILE.			30138554	I WILL REPLACE TILE	27/05/24	MC
AED HAZARDOUS KITCHEN		PADS EXPIRED FOR AED				NOTIFY HR. / CHURCH TO REFRESH.		
BSMT NEWS WASHROOM		SHOWER LOCKED REQUIRE KEY ONSITE / DESK.				MAKE SURE KEY AT FRONT DESK.		
LAUNDRY ROOM	BSMT	- SOME FLAMMABLE MATERIALS IN ROOM (VARNISH ETC)						
LAUNDRY ROOM		WINDOW WILL NOT LOCK.			30138569	W.O TO REPLACE HASP.	27/05/24	MC



January 8, 2025



Effie Slapnicar
Bursar & Chief Administrative Officer

Date

***Hazard Class:**

Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less than Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building:	ST. BASICS CATHEDRAL	Names of Inspectors: M. GUHAM	Names of Inspectors: PETER SKREPICHUK
First Aid Box Checked?	<input checked="" type="checkbox"/> Yes / No	Date: MAY 17, 2024	Signed:
Eyewash Station Checked?	<input checked="" type="checkbox"/> Yes / No	Signed: 	Signed: 

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
STORAGE		PEELING PAINT. REQUIRES PATCHING	PAINT CHIPS GETTING IN TOYS ETC.			PAINTER TO REMOVE & REPAINT. DISCUSS WITH STEVE. C.		





January 8, 2025

Effie Slapnicar
 Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building:	EH, MH, FS, UB + Teefy Hall	Names of Inspectors:	Lang He	Names of Inspectors:	Joao Santos
First Aid Box Checked?	Yes / <input checked="" type="radio"/> No	Date:	Signed:	Signed:	
Eyewash Station Checked?	Yes / <input checked="" type="radio"/> No	3/4, 2/5, 4/5, 6/5-27			

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
EH	106 218	bed was raised by bed risers.	- injury - property damage	B	—	Lowered.	3/6	J.S.
EH	423	door closing very fast	- injury	C	—	door closer adjusted	31/5	G.H.
MH	16	door closing very fast	- injury	C	—	door closer adjusted	31/5	G.H.
UB	406	door closing very fast	- injury	C	—	door closer adjusted	31/5	G.H.



January 8, 2025


Effie Slapnicar
 Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Sorbara Res.

Building:	Sorbara Res.	Names of Inspectors:	John Santos	Names of Inspectors:	
First Aid Box Checked?	Yes / No	Date:	June 24/25 - 2024	Signed:	
Eyewash Station Checked?	Yes / No				

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
Bmt	02	electrical cover missing	-	-	-	-	June 24	J.S.
Bmt	03	Door closer Repair				-	June 25	J.S.
4th Floor	403	Door closer Repair	-	-	-	-	June 25	J.S.
4th Floor	419	Door closer Repair	-		-			



January 8, 2025

Effie Slapnicar
 Bursar & Chief Administrative Officer

Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.



UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building:	CR + ier offices	Names of Inspectors:	GABRIELE	Names of Inspectors:	Joanne Grunata
First Aid Box Checked?	Yes / <u>NO</u>	Date:	June 28, 2024	Signed:	<i>[Signature]</i>
Eyewash Station Checked?	Yes / <u>NO</u>			Signed:	<i>[Signature]</i>

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
404	404	Access NW roof through a window in this room	Climb a chair & through a window is not a proper way a special ladder should be looked into	B	N/A	N/A		


[Signature]
 Effie Slapnicar
 Bursar & Chief Administrative Officer

January 8, 2025
 Date

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less than Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	ALUMNI HALL	Names of Inspectors: Emil Iruthayathas	Names of Inspectors:
First Aid Box Checked?	Yes/No <input checked="" type="radio"/> Yes / <input type="radio"/> No	Date: 04/18/24	Signed:
Eyewash Station Checked?	Yes/No <input checked="" type="radio"/> Yes / <input type="radio"/> No	Signed: 	Signed:

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
2nd Floor		couldn't locate first aid box	need 1st aid box	C		- email chanelle. First aid box - in staff lounge (Dec. 12, 2024)		N.a.
3rd Floor	305	1st aid box not visible	make the box visible	D		- First aid list indicates location. - Hang it on the wall		N.A.
1st Floor		may need an eyewash station	Put an eye wash station near clear room	D		- Michael Chow initiated distribution of small personal eyewash bottles across campus including AH. - email facilities team		N.A.

C.B.

C.B.

C.B.



January 13, 2025

Emil Slapnicar
Chairman & Chief Administrative Officer

Date _____

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

PIMS

	Names of Inspectors: <i>Chanelle</i>	Names of Inspectors: <i>John</i>
No / No	Date: Apr 17, 2024	Signed: <i>Chanelle</i> / <i>John Santos</i>

Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
					Date	Initials
<i>Common Room</i> ^{<i>Boardroom</i>} ^{<i>Kitchen</i>}	<i>Nothing to report</i>				<i>N.A</i>	<i>C.B.</i>
<i>Printer Room</i>	<i>"</i>					
<i>Offices</i>	<i>"</i>					
<i>Stairwell</i>	<i>"</i>					
<i>Library</i>	<i>- Staircase handrail Cerebral one sided handrail</i>	C		<i>No action required - employees should exercise caution.</i>	<i>N.A</i>	<i>C.B.</i>

Effie January 8, 2025

Effie Slapnicar Date
Bursar & Chief Administrative Officer

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

<i>Brennan Hall</i>		Names of Inspectors: <i>Chanella Burris</i>	Names of Inspectors: <i>John Santos</i>
No / No	Date: <i>April 23</i>	Signed: <i>Chanella Burris</i>	Signed: <i>John Santos</i>

Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
					Date	Initials
<i>Coop</i>	<i>N/A</i>					
<i>SUSSU Boardroom</i>	<i>N/A</i>					
<i>boardroom</i>	<i>N/A</i>					
<i>Bo 200</i>	<i>N/A</i>					
<i>SCR</i>	<i>N/A</i>					
<i>Kitchen hallway</i>	<i>Crowded / fall Collision hazard.</i>	<i>C</i>		<i>3rd party - would be dealt with Chartwells. Management aware of hazard.</i>	<i>N.A.</i>	<i>C.B</i>

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.




January 8, 2025

UNIVERSITY OF ST. MICHAEL'S COLLEGE

Joint Health and Safety Committee – Workplace Inspection Report

Building:	Founders House – 1 Elmsley place	Date: March 28, 2024	
First Aid Box checked?	Y / N	Name of Inspector: Chanelle Burris Joao Santos	Signed: Chanelle Burris, John Santos
Eyewash Station checked?	Y / N		

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
Basement		Nothing to report					N.A	C.B.
First Floor		Nothing to report						
Second Floor		Nothing to report						
Third Floor		Nothing to report						




Effie Slapnicar
Bursar & Chief Administrative Officer
 Date _____

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.

UNIVERSITY OF ST. MICHAEL'S COLLEGE
Joint Health and Safety Committee – Workplace Inspection Report

Building:	Odette Hall – 50 St. Joseph St	Name of Inspector: Chanelle Burris	Name of Inspector: Joao Santos
First Aid Box checked?	Y / N	Date: March 28, 2024	Signed: John Santos
Eyewash Station checked?	Y / N	Signed: Chanelle Burris	

Area	Room	Description	Potential Hazard / Recommendation	Hazard Class*	Work Order #	Corrective Action Planned	Work Complete	
							Date	Initials
Basement		Nothing to Report					N.A	C.B.
First Floor		Nothing to Report						
Second Floor		Nothing to Report						
Third Floor		Nothing to Report						



Effie Slapnicar
Bursar & Chief Administrative Officer
 Date _____

***Hazard Class:**
 Class "A" – Potential for permanent disability, loss of life, body part, and or extensive loss of structure equipment or material.
 Class "B" – Potential for Serious injury, illness, or property damage that is disruptive, but less then Class "A".
 Class "C" – Potential for injury, illness, or disruptive (non-disabling) property damage.
 Class "D" – No potential of injury / illness. However, does require follow-up & remedy.